

ADDENDUM TO: INSTALLATION INSTRUCTIONS FOR VISTA-50P/VISTA-50PUL
USE WITH ISSUE N5944-6

RE: UL LISTINGS / IMPORTANT NOTES

*** UL LISTING INFORMATION ***

The VISTA-50P has received the following UL Listings:

UL985 Household Fire
UL1023 Household Burglary

Additionally, the VISTA-50PUL has received the following UL Listings:

UL609 Grade A Local Mercantile Premises/Local Mercantile Safe & Vault
UL365 Police Station Connected Burglar Alarm
UL1610 Central Station Burglar Alarm

*** IMPORTANT NOTES ***

1. Audio Alarm Verification (AAV), as mentioned on pages 4 and 69 of the Installation Instructions, is not permitted in UL installations.
2. Page 103 of the Installation Instructions refers to program fields 1*40 and 1*41 as EVENT LOGGING DIALER CODES. These should be referred to as NON-ALARM DIALER CODES.

ADEMCO
ALARM DEVICE MANUFACTURING CO.
A DIVISION OF PITTMAY CORPORATION
165 Eileen Way, Syosset, New York 11791
Copyright © 1995 PITTMAY CORPORATION